

LIGHTING CONTROL MATRIX (University of Nebraska - Lincoln)

The following schedule pertains to University of Nebraska – Lincoln (UNL) city and east campus buildings (excluding campus housing). It is the A/E’s responsibility to include this schedule in the construction document plans or specifications.

The coordination schedule for UNL Housing or outstate buildings shall be coordinated project-by-project basis.

	=	=	=	=	=	=	=
Cs-Auditori	X			X		X	
Locer R	XXX						
Cs-non Audiori	X		X			X	
Cerence R	X		X			X	
Pint/C R	X		X			X	
Beak Room	X		X			X	
Private Office	X		X			X	
Open Office	X		X			X	
Workshop	X		X			X	
Warehouse	X		X			X	
Storage	X		X			X	
Lab-Class	X		X			X	
Lab-Non-class	X		X			X	
Corridor	X			Note 3			X
Lobby - Elevator	X			Note 3			X
Lobby - Non-elevator	X			Note 3			X
Mech/Elec/IT Closets	X						LTG CTRL '4' Local control, provide with 24/7 nightlight
Restroom		X				X	
Stairwell		X				X	
							SCHEME #

Matrix Notes:

- 6. Daylight Harvesting: Though not noted above, all applicable spaces that have daylighting shall include daylight harvesting per code.
- 7. 24/7 Nightlight & Egress Lighting: Some lights to remain on when needed for egress, safety, security, etc. Code exceptions apply. A minimum level of 24/7 night lighting is expected in corridors, mech/elec spaces, lobbies, etc.
- 8. 3rd Party Integration: Some spaces will require audio & visual system interface. Provide interface per specifications and as required per project.